

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013745  
DATE: 06/06/2017  
CERTIFICATION PROGRAM: Fire  
COMPANY: Seves Glass  
CODE: 2322-1  
EXPIRATION DATE: 06/30/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Seves Glass Block, Inc.</b> <b>10576 Broadview Road</b> <b>Broadview Heights, OH 44147</b>	<b>Series "Nubio Thickset 90"</b> <b>Fire-Rated Glass Block</b> Manufacturer Specific Glass Blocks for Installation in 60 Minute Locations  Max Opening: 100ft <sup>2</sup> or W-120" or H-120"  Glass Block Weight: 6.8 lb  Glass Block Size: 8" x 8" Minimum Thickness: 3.88" Minimum Face Thickness: 7/16"

SPECIFICATION	PRODUCT RATING
<b>ANSI/UL 9</b>	<b>90 Minutes</b> <b>With Hose Stream</b>

TEST REPORT
Underwriters Laboratory Test Report No: R2556 00NB21799, R2556 79NK1, R2556 91NK10106, R2556 95NK20176

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122

